

LE 75L LIQUID HANDLING ASSEMBLY

CAUTION

When pumping chemicals make certain that all tubing is securely attached to the fittings. It is recommended that tubing or pipe lines be shielded to prevent possible injury in case of rupture or accidental damage. Always wear protective clothing when working on or near chemical metering pump.

MATERIAL

Fittings	Polypropylene
Seal Rings	Polyprel™
Balls	Ceramic
Head	Polypropylene
Liquifram	Teflon Face
Suction	.5" OD Polyethylene
Discharge	.5" OD Polyethylene

A. INSTALLING INJECTION CHECK VALVE

1. The injection check valve should always be installed as close as possible, to the point of chemical injection, at the very end of the tubing run.
2. Purpose of injection check valve is to prevent backflow from treated line.
3. A ½" NPT female fitting with sufficient depth will accept the injection check valve.
4. In order to insure correct seating of the ball inside the check valve, the injection check valve should be installed upwards.

B. CONNECTING DISCHARGE TUBING

Note: Cut tubing to length needed for discharge line making sure sufficient amount is left for suction line.

1. Route tubing from injection check valve to chemical metering pump making sure it does not touch hot surfaces, sharp surfaces, or is bent so sharply that it kinks.
2. Slide small end of coupling nut onto tubing.
3. Push tubing over tapered nozzle of discharge valve housing so that tubing flares out and reaches the shoulder. (If tubing is stiff from cold, dip end in hot water.)
4. Slide down the coupling nut until threads are engaged. Tighten by hand until tubing is held securely in place.

Excessive force will crack or distort fittings. DO NOT USE PIPE WRENCH.

5. Follow the same procedure for connecting tubing to injection valve.

C. CONNECTING SUCTION TUBING

1. Cut suction tubing to a length such that the foot valve hangs just above the bottom of the chemical container. Maximum recommended vertical suction lift is 5 ft. (1.5m).

2. Follow same procedure (see B) in connecting suction tubing to suction valve and foot valve.
3. If a suction tube straightener is desired, one may be fabricated from a 3 ft. (1m) piece of ¾" Schedule 80 PVC pipe.
4. Dip end of PVC pipe in hot water for at least 1 minute.
5. Push pipe over small end of coupling nut.

D. PRIMING

1. Temporarily remove tubing from injection check valve and hold the end of tubing so it is above pump level.
2. Set pump at maximum speed and 100% stroke and start pump.
3. As soon as chemical is visible through translucent discharge tubing just past the discharge valve, stop the pump.
4. Pump is now primed.
5. Reconnect tubing to injection check valve.

Note:

- (a) Pump is normally self-priming if suction lift is no more than 5 ft. (1.5m), valves in the pump are wet with water (pump is shipped from factory with water in pump head and therefore valves are wet), and the above steps (D1 thru D3) are followed.
- (b) If the pump does not self prime, remove discharge valve housing and ball and pour water or chemical slowly into discharge port until it is filled. Follow steps D2 thru D5 thereafter.



LIQUID METRONICS INCORPORATED

19 CRAIG ROAD • ACTON, MA 01720-5495, U.S.A. • 617-263-9800 • TELEX 95-1781 FAX: 617-264-9172

Use Teflon® tape only at this point.

1. Maximum pump pressure rating is reduced by 25 psi (1.7 bar) with back pressure spring installed.
2. Do not remove back pressure spring (if pressure at injection point is less than 20 psi (1.4 bar).

LE 75

Key No.	Part No.	Description	Quantity
1	29961	Injector Fitting	1
2	10339	Spring	1
3	10338	Ball, Ceramic	4
4	29443	Seal Ring	4
5	10792	Valve Seat, ivory Polypropylene	2
6	10411	Coupling Nut	4
7	10142-16	Tubing, Polyethylene, .5" OD	1
8	10793	Valve Housing, ivory Polypropylene	2
9	10304	Head, 1.8 SI, ivory, Polypropylene	1
10	10305	Liquifram, 1.8 SI Teflon Face	1
11	10340	Screw, 10-24 x ¾" S.S.	4
12	10322	Weight, Ceramic	1
13	10978	Foot Valve Seat	1
14	10123	Strainer, Polypropylene	1
15	29523	Injection Check/Back Pressure Valve Asm	1
18	29524	Foot Valve Assembly	1
19	29525	Head Assembly, LE 75T	1

